

CERTIFICATE

No. 687

Date 22-11-2022

It is Certified that an Inspection team headed by JEN Ms. Asha Meena from P.H.E.D. Pratap Nagar Jaipur Inspected the St. Mary's Senior Secondary Convent School on 14/11/2022 and found that the St. Mary's Senior Secondary Convent School has safe drinking water facilities for the student and members of staff on the institution and is maintaining the hygienic sanitation condition in the School Building & the Campus as per norms prescribed by the **NATIONAL SCHOOL SANTATION MANUAL of Central Govt.**

The above certificate is valid for a period of 12 month

Encl : Superintending Chemist PHED Lab

Sample Microbiological Test report letter no 8392 dt. 07/11/2022

Sample Chemical Test Report Letter no 8429 dt. 14/11/2022

Asha Meena
14/11/2022
प्रतापनगर नोकी II
नगर उपखण्ड XII (दक्षिण)
जन स्वा अभि. विभाग जयपुर

Ed
सहायक अभियन्ता
जन स्वास्थ्य अभियांत्रिकी विभाग
नगर उपखण्ड XII (दक्षिण)
प्रतापनगर सांगानेर, जयपुर
DDO CODE No.-10/005423

Signature with seal.....

Name: *स्तीराज वैरवा*

Designation- Assistant Engineer

PHED CP Sub Dn XII.. (South)

Pratap Nagar, Jaipur

Copy to :

Principal

St. Mary's Senior Secondary Convent School

Jagatpura, Jaipur



OFFICE OF THE CHIEF CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT, CENTRAL LABORATORY
Gandhi Nagar (Near Reserve Bank Quarters), Rajasthan, Jaipur - 302 015
REPORT OF THE BACTERIOLOGICAL EXAMINATION OF WATER

No: Lab/Bact/2022-23/ 8392


Dated: 07/11/2022

To
The Principal
St. Mary Convent Sr. Sec. School
Jagatpura,
Jaipur-302017

Reference :- Your Application on dated 01.11.2022
GRN NO. :- 67994729 Paid on Date 01.11.2022

Distt: Jaipur
Tehsil: Jaipur
Name of Sample Taker:- Sh. Suresh Tyagi

Sample No.	Date of Collection	Date of Examination	Residual Chlorine mg/l	Area	Particulars of Samples	Coliform Organisms MPN/100 ml	E-Coli Organism (MPN)	Remarks (Satisfactory/ Unsatisfactory)
P:55 ----- 2844	01.11.2022	01.11.2022	—	Jagatpura, Jaipur	RO Plant, St. Mary's Convent Sr. Sec. School, Jagatpura, Jaipur	Nil	Nil	Satisfactory


Superintending Chemist
PHED, Laboratory, Jaipur
Dated: 7/11/22

No: Lab/Bact/2022-23/
Copy to:
1. The Chief Chemist, PHED, Rajasthan, Jaipur

Superintending Chemist
PHED, Laboratory, Jaipur

OFFICE OF THE CHIEF CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT LABORATORY, GANDHI NAGAR, JAIPUR
REPORT OF THE CHEMICAL EXAMINATION OF WATER

No: Lab/Sup.Chem. (HM) / Jaipur (City) /2022-2023/

Date: 14/11/22

To,

St.Marys Convent Senior Sec. School 8429 -
 Jagatpura
 Jaipur

The Sample was not Collected
 by this Laboratory

Not Valid for water
 quality & Legal Cases

Date of Receipt 01-11-2022

Particulars			RO Plant St.Marys Convent Senior Sec. School Jagatpura Jaipur
	value as per I.S.:10500/2012		
Village / Town	Requirement (Acceptable Limit)	Permissible Limit in the absence of Alternate Source	Jaipur
Date of Collection			01-11-2022
Lab. Sample No.			P - 71
1. pH	6.5-8.5	6.5-8.5	7.41
2. Turbidity (NTU)	1	5	NIL
3. Colour (Hazen units)	5	15	None
4. Odour	Un Objectionable		U.O.
5. Total Alkalinity(as CaCO ₃) mg/l	200	600	60
6. Total Hardness (as CaCO ₃) mg/l	200	600	70
7. Calcium (as Ca) mg/l	75	200	10
8. Magnesium (as Mg) mg/l	30	100	11
9. Chloride (as Cl ⁻) mg/l	250	1000	30
10. Nitrates (as NO ₃ ⁻) mg/l	45	45	4
11. Sulphate (as SO ₄ ⁻²) mg/l	200	400	10
12. Total Dissolved Solids mg/l	500	2000	154
13. Fluoride mg/l	1.00	1.5	0.11
14. Iron mg/l	1.0	No Relaxation	NIL
15. Arsenic mg/l	0.01	No Relaxation	NIL

Remark- 1. All chemical parameters except pH are in mg/L
 2. Tested Results Relate only to The Samples send by you

C-1256
 14/11/22
 Superintending Chemist (Heavy Metal)
 P.H.E.D. Laboratory, Jaipur

No: Lab/Sup.Chem. (HM) / Jaipur (City) /2022-2023/

Date:

Copy to:-

1. The Chief Chemist, PHED Raj. Jaipur

Superintending Chemist (Heavy Metal)
 P.H.E.D. Laboratory, Jaipur